ARISH BABU R.R. M.Sc.,

Jalashakthi Ground Water & Borewell Consultant

S/6, Kiran Complex, Opp. Mangalore Independent College,
Ullala Main Road, Muneshwara Nagar, Jnanabharathi Post,
Bangalore - 560 056.

Mobile : 99801 94377
98443 72004
E-mail : arishbabu11@gmail.com

GROUND WATER INVESTIGATION / YIELD REPORT



No.:

Date : 05/05/2021

Name & Adress : Assistant Executive Engineer, T. Dasarahalli Subdivision
BBMP, Dasarahalli Zone

Purpose of Ground Water : Public Supply

Ground Water Potential : ① Pipeline Road, ② Bhyraveshwara Nagar

Site Location : ③ R.N Layout [Kempegowda Layout]

Topography : Plain Land

Soil : Granitic Schist, Black soil, Reddish

Rock below the soil : Black and white, Hard rock, Hard rock

Water Striking Levels

	1st Source	2nd Source	3rd Source	Casing	Yield
Point # 1	480 to 510 Ft.	520 to 610 Ft.	700 to 820 Ft.	200-250 Ft.	2500 to 2600 Gals/Hr.
Point # 2	700 Ft.	920 to 970 Ft.	Ft.	200-250 Ft.	2200 to 2400 Gals/Hr.
Point # 3	670 Ft.	840 to 980 Ft.	980 to 1110 Ft.	180-250 Ft.	2100 to 2300 Gals/Hr.
Point # 4	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 5	Ft.	Ft.	Ft.	Ft.	Gals/Hr.
Point # 6	Ft.	Ft.	Ft.	Ft.	Gals/Hr.

Note : Although the best site for drilling has been suggested. NO GUARANTEE of success can be given and we will not be liable in any way for any loss to the party in respect of the well drilled at the recommended being failure.

(ARISH BABU R.R.)
Consultant Geologist / Diviner

Scanned with CamScanner